

**PROFOMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. - 07/24

Date: 09.07.2024

It is Certified that an inspection team headed by **Beena Ambika Chemist/Lab Incharge.**

(Name of officers with designation) from **U.P. Jal Nigam (Rural) Ghazipur.**

(Name of Department/ Office) Inspected the Water M/S **Divine Global School Village- Harpur, Block- Zamania, DIST- Ghazipur (U.P.)**.

(Name & Address of the School) on 09.07.2024 (Date of inspection) and found that the

**Divine Global School** (Name of school) has safe drinking water.

Facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/ U.T. Govt.

The above is valid for a period of **06 Months.**

Signature with Seal

Name: Beena Ambika

Designation: Chemist/Lab Incharge.

Name &amp; Address of the Office / Department: UP JN (R)



To,

**Divine Global School**

Village- Harpur, Block- Zamania, Dist- Ghazipur .

(Name &amp; Address of the Institution)

\*The filled up certificate should be either in Hindi or English. If It is issued in vernacular language. Translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.





# TEST REPORT

District Level Water Analysis Laboratory,  
Uttar Pradesh Jal Nigam, (Rural), Ghazipur, 233001

Report No.	GZP/D.W/24/07/32	Date-09.07.2024	S. No-32	Page No-2	Page No.-2/2
------------	------------------	-----------------	----------	-----------	--------------

### Customer Details

Office Name and Address	M/S Divine Global School Village- Harpur Block- Zamania DIST- Ghazipur (U.P.)
Ref. Letter No. & Date	

### Basic Details of sample

District	Ghazipur	Block	Zamania
Gram Panchayat	Harpur	Village	Harpur
Habitation	Harpur	Location	Harpur
Water Source	Drinking Water	Sample No.	32
Quantity of Sample	2 L	Date of S.C.	05.07.2024
Receiving Date	05.07.2024	S. Collector	Sunil Kumar
Sample Depositor	Sanjay		
Analysis Start Date	06.07.2024		

Analysis Completion Date- 08.07.2024

### Environmental Condition

Temperature	23.4°C	Relative Humidity	46.6%
-------------	--------	-------------------	-------

### Technical Data of Analysis

S. No.	Analyses parameters(Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Sulphate (mg/L)	25.00	200	400	APHA 24 Edition-4500SO4 method (Turbidity meter)2023
2	Nitrate(mg/L)	20.00	45	-	APHA 24 Edition-4500-NO3-B method
3	Fluoride (mg/L)	0.50	1	1.5	APHA 24rd Edition -4500-F Method C (Electrode Method) : 2023
4	Iron (mg/L)	0.02	0.3	-	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023
5	Residual Chlorine (FRC)	BDL	0.2	1	DPD Tablet Method
6	Odour	Agreable	Agreable	Agreable	IS 3025 (Part 5):2021
7	Color (Hazen)	<5	5	15	IS 3025 (Part 4) : 2021
8	E. coli (CFU/100ml)	Absent	0	0	H2S Vials

- Note -
1. This certificate refers only to the particular sample (S) submitted for testing.
  2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
  5. BDL- Below Detection Limit.
  6. UDL- Upper Detection Limit.
  7. \*indicates parameters that are NABL accredited.



Report Prepared by  
Laboratory Contact details-Email- upjn1districtlabgzp@gmail.com Contact: 7839113691

\*\*End of Test Report\*\*





# TEST REPORT

District Level Water Analysis Laboratory,  
Uttar Pradesh Jal Nigam, (Rural), Ghazipur, 233001



TC-12315

Report No.	GZP/DW/24/07/32	Date-	09.07.2024	S. No-	32	Page No-	1	Page	1/2
<b>Customer Details</b>									
Office Name and Address	M/S Divine Global School Village- Harpur Block- Zamania DIST- Ghazipur (U.P.)								
Ref Letter No & Date									
<b>Basic Details of sample</b>									
District	Ghazipur	Block	Zamania						
Gram Panchayat	Harpur	Village	Harpur						
Habitation	Harpur	Location	Harpur						
Water Source	Drinking Water		Sample No.	32					
Quantity of Sample	2 L		Date of S.C.	05.07.2024					
Receiving Date	05.07.2024		S. Collector	Sunil Kumar					
Sample Depositor	Sanjay								
Analysis Start Date	06.07.2024		Analysis Completion Date- 08.07.2024						
<b>Environmental Condition</b>									
Temperature	23.4°C			Relative Humidity	46.6%				
<b>Technical Data of Analysis</b>									
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis				
			Acceptable Limit	Permissible Limit					
1	2	3	4	5	6				
1	pH@25°C	7.65	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2012				
2	Turbidity (NTU)	3.28	1	5	IS 3025 (Part 10): 2017				
3	TDS (mg/L)	389.10	500	2000	IS 3025 (Part 16): 2023				
4	Chloride (mg/L)	31.99	250	1000	IS 3025 (Part 32): 2019				
5	Total Alkalinity (mg/L)	124.00	200	600	IS 3025 (Part 23): 2019				
6	Total Hardness (mg/L)	218.00	200	600	IS 3025 (Part 21): 2019				
7	Calcium (mg/L)	102.00	75	200	IS 3025 (Part 40): 2019				
8	Magnesium(mg/L)	28.18	30	100	IS 3025 (Part 46): 2019				
Note - 1. This certificate refers only to the particular sample (S) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been Obtained from Head of Laboratory. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.									
Report Prepared by _____ Laboratory Contact details-Email- upjn1districtlabgzp@gmail.com									

\*\*End of Test Report\*\*

